

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
BONALBO	18/07/2018	40	15	2	2420	4.5	4.1
	22/08/2018	79	40	2	4	7.5	2.6
	19/09/2018	92	29	2	1986	5.4	2.4
	17/10/2018	46	17	2	141360	6.9	3.3
	21/11/2018	73	24	2	248	5.2	2
	12/12/2018	91	68	5	1733	11	3.7
	17/04/2019	20	14	2	1986	4.7	4.5
	Min	20.0	14.0	2.0	4.0	4.5	2.0
	Avg	63.0	29.6	2.4	21391.0	6.5	3.2
	Max	92.0	68.0	5.0	141360.0	11.0	4.5