

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
BONALBO	20/07/2016	126	45	2	712	9.7	5.3
	17/08/2016	34	20	2	300	6.2	2.3
	23/11/2016	111	25	2	126	5.7	2.1
	14/12/2016	86	25	2	2	4.1	3
	18/01/2017	79	15	2	146	2.6	1.4
	22/02/2017	62	14	3	7270	6.1	3.1
	22/03/2017	60	21	9	7701	7.6	2.8
	19/04/2017	80	24	2	591	6.7	3.6
	<b>Min</b>	34.0	14.0	2.0	2.0	2.6	1.4
	<b>Avg</b>	79.8	23.6	3.0	2106.0	6.1	3.0
<b>Max</b>	126.0	45.0	9.0	7701.0	9.7	5.3	