

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5
KYOGLE	20/07/2016	5	5	2	400	6.5	1.9
	17/08/2016	4	4	2	320	7.3	1.9
	23/11/2016	14	6	2	128	2.3	3.2
	14/12/2016	1	2	2	700	1.4	2.5
	18/01/2017	32	4	2	2420	5.1	6.4
	22/02/2017	6	3	2	379	4.6	5
	22/03/2017	1	2	2	1935	3.5	2.3
	19/04/2017	4	2	2	432	3.5	1
	Min	1.0	2.0	2.0	128.0	1.4	1.0
	Avg	8.4	3.5	2.0	839.3	4.3	3.0
Max	32.0	6.0	2.0	2420.0	7.3	6.4	