

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
BONALBO	20/07/2011	14	3	2	85	1.7	4
	17/08/2011	10	5	2	12	1.3	4.5
	28/09/2011	12	3	2	4	1.6	6.5
	19/10/2011	19	5	2	80	1.4	6.5
	23/11/2011	16	6	2	2	1.7	7.5
	14/12/2011	26	15	2	28	3	4.5
	18/01/2012	21	7	2	70	2.6	5
	22/02/2012	9	5	2	848	1.8	2.5
	21/03/2012	8	2	2	66	2.5	2.5
	18/04/2012	84	14	2	240000	16	8
	23/05/2012	22	6	2	2	4.15	10.05
	20/06/2012	16	2	2	8	3.2	1.9
	<b>Min</b>	8.0	2.0	2.0	2.0	1.3	1.9
	<b>Avg</b>	21.4	6.1	2.0	20100.4	3.4	5.3
<b>Max</b>	84.0	15.0	2.0	240000.0	16.0	10.1	