

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
BONALBO	18/07/2012	10	2	2	4	2.5	2
	22/08/2012	18	3	2	1	1.6	2.9
	19/09/2012	16	4	2	36	1.7	5.5
	17/10/2012	82	27	3	500	5.6	8.9
	14/11/2012	71	22	2	8	5.8	11
	5/12/2012	25	17	2	60	6.5	9
	20/02/2013	35	10	2	2450	3	7.5
	20/03/2013	38	10	2	70	3.1	3
	8/05/2013	17	8	2	20	2.3	2.6
	22/05/2013	14	6	2	60	2.1	2.1
	26/06/2013	41	11	2	3500	7.7	2.3
	Min	10.0	2.0	2.0	1.0	1.6	2.0
	Avg	33.4	10.9	2.1	609.9	3.8	5.2
Max	82.0	27.0	3.0	3500.0	7.7	11.0	