

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	
BONALBO	17/07/2013	7	2	2	6	2.5	3	
	21/08/2013	23	7	2	3600	5.6	6.5	
	18/09/2013	22	8	2	44	3.5	4.6	
	23/10/2013	19	7	2	92	2.2	5.3	
	20/11/2013	29	8	2	7	3.2	3.2	
	4/12/2013	38	12	2	10	3.5	3.9	
	15/01/2014	44	11	2	5	3.6	4.1	
	19/02/2014	32	11	2	90	3.2	3.2	
	13/03/2014	70	18	2	13600	4.9	4.9	
	9/04/2014	19	6	2	6	1.9	4.7	
	21/05/2014	54	20	2	295	4.1	5.4	
	18/06/2014	48	13	2	370	9.3	5.3	
	Min		7.0	2.0	2.0	5.0	1.9	3.0
	Avg		33.8	10.3	2.0	1510.4	4.0	4.5
Max		70.0	20.0	2.0	13600.0	9.3	6.5	