

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
BONALBO	16/07/2014	76	12	2	3500	10	3.7
	20/08/2014	95	46	3	680	8.1	5.8
	17/09/2014	135	55	2	440	9.8	5
	22/10/2014	56	18	2	700	5.2	5.5
	19/11/2014	80	12	2	170	4.7	4.4
	17/12/2014	50	18	2	422	3.7	3.3
	21/01/2015	45	8	2	11000	4.9	4.4
	18/02/2015	50	12	2	1500	3.6	3.6
	18/02/2015	21	7			2.36	3.59
	18/03/2015	55	12	2	400000	7.6	4.3
	22/04/2015	52	10	2	7	3.8	3.9
	20/05/2015	45	12	3	4000	4.2	5
	17/06/2015	17	5	2	49200	6.3	6.4
		Min	17.0	5.0	2.0	7.0	2.4
	Avg	59.8	17.5	2.2	39301.6	5.7	4.5
	Max	135.0	55.0	3.0	400000.0	10.0	6.4

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
---------------	-----------	---	---	--	---	---------------------------------	-----------------------------------