

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
BONALBO	22/07/2015	10	6	2	9800	10	5
	19/08/2015	54	6	2	1192	5.5	3.8
	23/09/2015	33	19	2	1168	5.9	6.8
	21/10/2015	69	17	2	143	4.9	4.8
	4/11/2015	26	7	0	0	2.43	3.18
	18/11/2015	144	17	2	2	4	3.2
	16/12/2015	37	10	2	2600	4.6	4.2
	20/01/2016	75	21	2	17000	5.2	3.3
	17/02/2016	21	12	2	4300	4.5	4.3
	23/03/2016	32	18	2	4	3.9	4.1
	20/04/2016	48	25	2	1170	4.9	3.4
	18/05/2016	58	20	2	3000	6.3	4.6
	22/06/2016	51	23	2	5600	8.3	3.2
		<b>Min</b>	10.0	6.0	0.0	0.0	2.4
	<b>Avg</b>	50.6	15.5	1.8	3536.8	5.4	4.1
	<b>Max</b>	144.0	25.0	2.0	17000.0	10.0	6.8