

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	
KYOGLE	20/07/2011	3	2	2	620	7.1	1.6	
	17/08/2011	5	3	2	720	6.7	3	
	7/09/2011	2	2			4.9	1.9	
	5/10/2011	7	2			5.3	0.86	
	9/11/2011	14	2			7	0.54	
	23/11/2011	9	2	2	700	8.5	0.23	
	7/12/2011	4	2			5.7	0.99	
	14/12/2011	4	2	2	452	5.7	0.83	
	10/01/2012	1	2			6.2	0.44	
	18/01/2012	1	2			4.2	0.45	
	8/02/2012	4	2			9.7	0.2	
	22/02/2012	13	2	2	3840	6.3	3.5	
	7/03/2012	4	2			3.5	0.45	
	11/04/2012	7	3			6.3	2.1	
	9/05/2012	1	3			8	2.5	
	23/05/2012	3	2	2	50	7	2.13	
	6/06/2012	2	2			12	1.1	
	20/06/2012	1	2	2	320	6.2	1.1	
		Min	1.0	2.0	2.0	50.0	3.5	0.2
		Avg	4.7	2.2	2.0	957.4	6.7	1.3
	Max	14.0	3.0	2.0	3840.0	12.0	3.5	