

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	
KYOGLE	4/07/2012	3	2	2		16	0.86	
	18/07/2012	2	2	2	50	10	0.77	
	8/08/2012	3	2	2		14	0.91	
	22/08/2012	2	2	2	1640	17	0.53	
	19/09/2012	1	2	2	710	7.9	1.7	
	3/10/2012	3	2	2		7.6	2.3	
	17/10/2012	1	2	3	118	10	2.4	
	14/11/2012	7	2	2	370	4.2	2.5	
	5/12/2012	6	2	2	176	2.5	2.4	
	20/02/2013	26	10	2	412000	7.2	2.2	
	20/03/2013	4	2	2	1500	2.1	1.9	
	17/04/2013	11	5	2	10000	4	1.9	
	22/05/2013	4	2	2	2500	13	3.2	
	26/06/2013	5	5	2	5500	30	1.3	
	<b>Min</b>		1.0	2.0	2.0	50.0	2.1	0.5
	<b>Avg</b>		5.6	3.0	2.1	39505.8	10.4	1.8
<b>Max</b>		26.0	10.0	3.0	412000.0	30.0	3.2	