

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5
KYOGLE	17/07/2013	15	2	2	2300	8.8	2.1
	21/08/2013	4	2	2	260	7.7	3.7
	18/09/2013	4	2	2	7000	7.2	3.5
	23/10/2013	9	2	2	480	2.4	3.9
	27/11/2013	7	2	2	172	1.4	4.6
	4/12/2013	8	3	2	13300	2.3	5.8
	15/01/2014	38	4	2	700	4.5	7.9
	5/02/2014	2	2			2.89	5.65
	19/02/2014	4	2	2	1180	2.2	5.2
	12/03/2014	25	2	2	600	2.4	4.2
	9/04/2014	6	2	2	1580	1.4	2.3
	21/05/2014	6	4	2	23800	9.2	3.9
	18/06/2014	6	6	2	840	7.2	4
	Min		2.0	2.0	2.0	172.0	1.4
Avg		10.3	2.7	2.0	4351.0	4.6	4.4
Max		38.0	6.0	2.0	23800.0	9.2	7.9