

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5
KYOGLE	16/07/2014	25	3	2	388	10	3.5
	20/08/2014	3	2	2	124	8.9	3.4
	17/09/2014	5	2	2	208	6.7	2.3
	22/10/2014	2	2	3	320	2.8	4.7
	19/11/2014	2	2	2	356	2.8	8.1
	17/12/2014	4	3	2	412	3.1	6.9
	21/01/2015	7	2	2	564	5	7.3
	18/02/2015	7	2	2	608	2.6	2.1
	18/03/2015	19	5	2	88000	9.9	2.3
	22/04/2015	2	2	2	250	7.5	1.1
	20/05/2015	4	2	2	170	10	2.3
	17/06/2015	1	2	2	146	8.1	3.4
	Min	1.0	2.0	2.0	124.0	2.6	1.1
	Avg	6.8	2.4	2.1	7628.8	6.5	4.0
	Max	25.0	5.0	3.0	88000.0	10.0	8.1

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5