

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	
KYOGLE	1/07/2015	3	2			10	3.3	
	8/07/2015	1	2			8	2.7	
	15/07/2015	5	2			12	2.5	
	22/07/2015	3	2	2	206	17	2	
	19/08/2015	3	2	2	56	0.16	1.3	
	23/09/2015	1	2	2	1500	7.2	1.7	
	21/10/2015	11	4	2	130	3.4	2.4	
	18/11/2015	4	2	2	1420	1.5	1.5	
	16/12/2015	1	2	2	940	4	1.4	
	20/01/2016	2	2	2	250	2	1.7	
	17/02/2016	14	10	2	415000	5.7	1.8	
	23/03/2016	23	21	3	110000	9.9	2	
	20/04/2016	2	2	2	190	5.6	1	
	18/05/2016	14	10	2	20000	7.9	1.9	
	22/06/2016	22	13	2	57000	17	2.4	
		Min	1.0	2.0	2.0	56.0	0.2	1.0
		Avg	7.3	5.2	2.1	50557.7	7.4	2.0
	Max	23.0	21.0	3.0	415000.0	17.0	3.3	