

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
WOODENBONG	18/07/2012	11	2	2	2	1.6	0.44
	22/08/2012	6	2	3	1	1.7	0.48
	19/09/2012	2	2	2	2	1.7	0.55
	17/10/2012	3	2	2	62	1.7	0.6
	14/11/2012	12	2	2	158	1.6	0.64
	5/12/2012	7	2	5	26	1.7	0.67
	20/02/2013	5	2	2	168	2.7	1.5
	20/03/2013	6	2	2	144	2.3	1.1
	17/04/2013	1	2	2	132	1.9	0.91
	22/05/2013	6	2	2	8	1.7	0.68
	26/06/2013	49	17	2	168	3.9	1.3
	<b>Min</b>	1.0	2.0	2.0	1.0	1.6	0.4
	<b>Avg</b>	9.8	3.4	2.4	79.2	2.0	0.8
<b>Max</b>	49.0	17.0	5.0	168.0	3.9	1.5	