

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	
WOODENBONG	17/07/2013	4	3	2	2	3.4	1.1	
	21/08/2013	3	2	2	3	5.3	1.3	
	18/09/2013	16	3	2	19	2.4	0.79	
	23/10/2013	29	10	2	6	2.8	1.8	
	20/11/2013	24	7	2	6	2.2	2.3	
	4/12/2013	2	2	2	10	1.1	0.39	
	15/01/2014	1	2	2	4	1.8	0.53	
	19/02/2014	3	2	2	4	1.8	0.23	
	12/03/2014	3	2	2	84	2	0.3	
	9/04/2014	2	2	2	38	2.1	0.28	
	21/05/2014	1	3	2	6	2	0.22	
	18/06/2014	1	2	2	1	2.1	0.21	
	Min		1.0	2.0	2.0	1.0	1.1	0.2
	Avg		7.4	3.3	2.0	15.3	2.4	0.8
Max		29.0	10.0	2.0	84.0	5.3	2.3	