

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
WOODENBONG	16/07/2014	1	2	2	2	2.6	0.26
	20/08/2014	4	2	2	2	2.8	0.24
	17/09/2014	2	2	2	2	2.9	0.22
	22/10/2014	2	2	2	1	3.3	0.19
	19/11/2014	2	2	2	1	2.9	0.15
	17/12/2014	6	2	2	1	4.4	0.25
	21/01/2015	4	2	2	3	4.1	0.26
	18/02/2015	1	2	2	16	2.8	0.52
	18/03/2015	21	3	2	30000	2.8	0.76
	22/04/2015	2	2	2	24	2.5	0.94
	20/05/2015	12	3	4	19	2.9	1
	17/06/2015	2	2	2	10	2.7	0.46
	Min	1.0	2.0	2.0	1.0	2.5	0.2
	Avg	4.9	2.2	2.2	2506.8	3.1	0.4
Max	21.0	3.0	4.0	30000.0	4.4	1.0	

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
---------------	-----------	---	---	--	---	---------------------------------	-----------------------------------