

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
WOODENBONG	22/07/2015	7	2	4	1	3	0.34
	19/08/2015	9	2	2	1	3.3	0.31
	23/09/2015	7	2	2	1	3.8	0.29
	21/10/2015	13	2	2	2	3.9	0.26
	3/11/2015	30	12			2.28	1.8
	18/11/2015	6	2	2	1	4.5	0.29
	16/12/2015	3	2	2	1	5.1	0.18
	20/01/2016	4	2	2	1	4.3	0.13
	17/02/2016	4	2	2	1	4	0.16
	23/03/2016	7	2	2	1	3.6	0.47
	20/04/2016	1	2	2	1	3.3	0.12
	18/05/2016	5	2	2	1	3.1	0.08
	22/06/2016	25	2	2	1	3.1	1.1
	Min		1.0	2.0	2.0	1.0	2.3
Avg		9.3	2.8	2.2	1.1	3.6	0.4
Max		30.0	12.0	4.0	2.0	5.1	1.8