

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	
BONALBO	19/07/2017	66	22	2	3045	6.3	8.6	
	23/08/2017	91	29	2	675	6.2	5.7	
	20/09/2017	86	30	2	6180	5.9	4.3	
	18/10/2017	28	20	2	60165	5.9	5.2	
	22/11/2017	64	16	2	545	4.3	2	
	13/12/2017	63	26	2	172	5.2	2.1	
	17/01/2018	70	23	2	135	4.7	2.1	
	21/02/2018	65	15	3	1165	6.7	2.2	
	21/03/2018	86	26	2	461	6.7	3.1	
	18/04/2018	69	34	2	225	6.9	1.9	
	16/05/2018	72	21	2	3190	6.4	4	
	<b>Min</b>		28.0	15.0	2.0	135.0	4.3	1.9
	<b>Avg</b>		69.1	23.8	2.1	6905.3	5.9	3.7
<b>Max</b>		91.0	34.0	3.0	60165.0	6.9	8.6	