

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	
KYOGLE	19/07/2017	14	5	2	352	5.4	1.1	
	16/08/2017	34	13	2	145	8.7	1.3	
	20/09/2017	2	5	2	155	7.1	2.7	
	18/10/2017	8	3	2	1795	4.3	1.6	
	22/11/2017	3	2	2	365	5.2	1.5	
	13/12/2017	8	2	2	114	5.5	1.4	
	17/01/2018	6	2	2	727	2.3	1.6	
	21/02/2018	9	2	2	579	1.8	1.7	
	21/03/2018	7	2	2	435	1.9	1.2	
	18/04/2018	10	2	2	2802	5.4	1.4	
	16/05/2018	4	2	2	52	8.1	1.4	
	<b>Min</b>		2.0	2.0	2.0	52.0	1.8	1.1
	<b>Avg</b>		9.5	3.6	2.0	683.7	5.1	1.5
	<b>Max</b>		34.0	13.0	2.0	2802.0	8.7	2.7