

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits
WOODENBONG	19/07/2017	10	2	2	1	2.2	0.23
	23/08/2017	14	2	2	1	1.3	0.23
	20/09/2017	9	2	2	1	1	0.18
	18/10/2017	16	2		1	1.3	0.23
	22/11/2017	33	2	2	24	2.4	0.38
	13/12/2017	12	2	2	1	1.8	0.31
	17/01/2018	21	3	2	1	2.5	0.35
	21/02/2018	20	2	2	1	2.6	0.31
	21/03/2018	10	10	2	120	3.2	1.5
	18/04/2018	4	3	2	1	2.6	0.99
		<b>Min</b>	4.0	2.0	2.0	1.0	1.0
	<b>Avg</b>	14.9	3.0	2.0	15.2	2.1	0.5
	<b>Max</b>	33.0	10.0	2.0	120.0	3.2	1.5