

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	
WOODENBONG	18/07/2018	1	2	2	1	1.9	0.39	
	22/08/2018	1	2	2	1	1.8	0.33	
	19/09/2018	2	2	2	1	2	0.35	
	17/10/2018	24	2	2	1	3.7	0.41	
	21/11/2018	18	2	2	1	2.7	0.41	
	12/12/2018	1	2	2	1	2.2	0.25	
	20/02/2019	22	2	2	1	4	1.5	
	20/03/2019	14	2	2	1	4.5	0.75	
	17/04/2019	12	6	2	5	8.8	0.6	
	22/05/2019	7	14	2	3	33	0.52	
	19/06/2019	2	15	2	1	54.1	0.51	
	Min		1.0	2.0	2.0	1.0	1.8	0.3
	Avg		9.5	4.6	2.0	1.5	10.8	0.5
Max		24.0	15.0	2.0	5.0	54.1	1.5	