

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	
BONALBO	18/07/2018	40	15	2	2420	4.5	4.1	
	22/08/2018	79	40	2	4	7.5	2.6	
	19/09/2018	92	29	2	1986	5.4	2.4	
	17/10/2018	46	17	2	141360	6.9	3.3	
	21/11/2018	73	24	2	248	5.2	2	
	12/12/2018	91	68	5	1733	11	3.7	
	16/01/2019	75	57	3	146	8.6	3.3	
	20/02/2019	58	12	2	2	5.6	1.6	
	20/03/2019	80	55	2	41	8.5	2.7	
	17/04/2019	20	14	2	1986	4.7	4.5	
	29/05/2019	30	14	2	1986	4.7	8.7	
	19/06/2019	32	21	2	3448	4.3	4.2	
	Min		20.0	12.0	2.0	2.0	4.3	1.6
	Avg		59.7	30.5	2.3	12946.7	6.4	3.6
Max		92.0	68.0	5.0	141360.0	11.0	8.7	