

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5
KYOGLE	4/07/2018	12	5	2	435	9.1	1.8
	18/07/2018	4	5	2	161	15	2.2
	1/08/2018	6	3	2	326	10	2.2
	22/08/2018	3	6	2	248	12	1.5
	5/09/2018	19	7	2	1300	10	1.6
	19/09/2018	6	2	2	345	9.1	1.4
	3/10/2018	7	2	2	727	6.5	1.3
	17/10/2018	11	9	2	32440	2.7	2
	7/11/2018	7	2	2	365	4.6	0.72
	21/11/2018	9	2	2	225	4.6	1.3
	5/12/2018	31	7	2	8212	2.6	3.9
	12/12/2018	39	5	2	114	2.7	4
	9/01/2019	17	2	2	131	3	3.9
	16/01/2019	13	2	2	272	1.5	3.7
	6/02/2019	6	2	2	727	1.6	3.6
	20/02/2019	14	2	2	291	1.3	2.6
	6/03/2019	6	2	2	308	1.2	2.2
	20/03/2019	7	2	2	517	3.4	2.3
	3/04/2019	7	2	2	291	5.2	2.2
	17/04/2019	12	3	2	16	5.9	1.9
1/05/2019	22	3	2	119	5.8	1.7	

# KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5
KYOGLE	22/05/2019	9	3	2	219	6.9	2
	5/06/2019	3	2	2	299	11	1.7
	19/06/2019	8	3	2	236	9.8	2
	<b>Min</b>	3.0	2.0	2.0	16.0	1.2	0.7
	<b>Avg</b>	11.6	3.5	2.0	2013.5	6.1	2.2
	<b>Max</b>	39.0	9.0	2.0	32440.0	15.0	4.0