

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE RECEIVED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
BONALBO	17/07/2019	24/07/2019	50	19	2	335	4	3.7	No discharge. Representative sample only
	14/08/2019	14/08/2019	81	31	2	58	5.8	3.4	No discharge. Representative sample only
	18/09/2019	18/09/2019	90	48	2	291	6.2	3.6	No discharge. Representative sample only
	16/10/2019	28/10/2019	34	19	2	15531	3.5	2	No discharge. Representative sample only
	27/11/2019	17/12/2019	93	35	2	365	7.7	3	No discharge. Representative sample only
	18/12/2019	23/12/2019	152	48	3	35	9.5	2.7	No discharge. Representative sample only
	18/12/2019	23/12/2019	152	48	3	38	9.5	2.7	No discharge. Representative sample only
	22/01/2020	22/01/2020	90	26	2	1	7.2	2.1	No discharge. Representative sample only
	19/02/2020	19/02/2020	46	30	2	2	7.4	1.9	No discharge. Representative sample only
	18/03/2020	18/03/2020	151	42	2	2	13	2.5	No discharge. Representative sample only

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE RECEIVED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
BONALBO	22/04/2020	28/04/2020	55	18	2	935	8.7	5.7	No discharge. Representative sample only
	20/05/2020	9/06/2020	82	19	2	710	6.7	6.2	
	17/06/2020	17/06/2020	44	24	2	993150	9.1	7.2	
	Min		34.0	18.0	2.0	1.0	3.5	1.9	
	Avg		86.2	31.3	2.2	77804.1	7.6	3.6	
	Max		152.0	48.0	3.0	993150.0	13.0	7.2	