

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE RECEIVED	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	COMMENTS
KYOGLE	3/07/2019	12/07/2019	5	4	2	325	9.4	1.4	Compliant
	3/07/2019	3/07/2019	5	4	2	325	9.4	1.4	Compliant
	17/07/2019	24/07/2019	3	6	2	248	9.3	1.5	Compliant
	7/08/2019	16/08/2019	4	7	2	53	9.1	2.2	Above 90%ile TP
	14/08/2019	14/08/2019	5	4	2	124	11	2.5	Above 90%ile TP
	11/09/2019	24/09/2019	5	6	2	59	10	2.7	Above 90%ile TP
	18/09/2019	18/09/2019	3	7	2	345	6.3	3.1	Above 90%ile TP
	16/10/2019	28/10/2019	1	7	2	59	6.5	5.2	Non Compliant TP. New pond under construction
	6/11/2019	18/11/2019	6	4	2	63	8.1	6.5	Non Compliant TP. New pond under construction
	20/11/2019	28/11/2019	8	4	2	1203	8.2	6	Non Compliant TP. New pond under construction
	4/12/2019	17/12/2019	9	4	2	75	7.3	5.7	Non Compliant TP. New pond under construction Rainfall event
	11/12/2019	19/12/2019	13	9	2	58	5.8	5.2	Non Compliant TP. New pond under construction Rainfall event
	8/01/2020	17/01/2020	4	5	2	104620	6.1	3.5	Above 90%ile Rainfall event
	22/01/2020	22/01/2020	1	3	2	884	5	1.7	Compliant
	5/02/2020	5/02/2020	5	7	2	1414	5.3	2	Compliant. New pond online
	19/02/2020	19/02/2020	2	3	2	9606	3.6	1.7	Compliant

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE RECEIVED	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	COMMENTS
KYOGLE	4/03/2020	4/03/2020	5	3	2	2046	3.2	1.3	Compliant
	18/03/2020	18/03/2020	1	2	2	387	4.9	1.2	Compliant
	1/04/2020	1/04/2020	3	2	2	1043	7.4	1.5	Compliant
	22/04/2020	28/04/2020	5	3	2	49	4.2	1.2	Compliant
	6/05/2020	12/05/2020	1	7	2	1	0.1	0.05	Compliant
	20/05/2020	9/06/2020	6	9	2	687	10	1.3	Compliant
	3/06/2020	12/06/2020	3	3	2	58	7.4	1	Compliant
	17/06/2020	17/06/2020	5	18	2	1414	12	1.7	Compliant
		Min	1.0	2.0	2.0	1.0	0.1	0.1	
		Avg	4.5	5.5	2.0	5214.4	7.1	2.6	
		Max	13.0	18.0	2.0	104620.0	12.0	6.5	