

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE RECEIVED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
WOODENBONG	17/07/2019	24/07/2019	5	75	2	1	41	0.59	No discharge. Representative sample only
	14/08/2019	14/08/2019	2	2	2	1	6.3	1.1	No discharge. Representative sample only
	18/09/2019	18/09/2019	5	2	2	1	3.6	1.3	No discharge. Representative sample only
	16/10/2019	28/10/2019	3	3	2	23	14	0.23	No discharge. Representative sample only
	27/11/2019	17/12/2019	10	2	2	1	12	0.44	No discharge. Representative sample only
	11/12/2019	19/12/2019	78	3	2	5	10	0.58	No discharge. Representative sample only
	22/01/2020	22/01/2020	57	2	2	579	8.8	0.39	No discharge. Representative sample only
	19/02/2020	19/02/2020	15	2	2	1120	6.4	0.31	No discharge. Representative sample only
	18/03/2020	18/03/2020	67	2	2	411	6.3	0.48	No discharge. Representative sample only
	22/04/2020	28/04/2020	24	2	2	16	7.3	0.44	No discharge. Representative sample only

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE RECEIVED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
WOODENBONG	20/05/2020	9/06/2020	17	2	2	2	4.7	0.3	No discharge. Representative sample only
	17/06/2020	17/06/2020	1	2	2	1	4.5	0.72	No discharge. Representative sample only
	Min		1.0	2.0	2.0	1.0	3.6	0.2	
	Avg		23.7	8.3	2.0	180.1	10.4	0.6	
	Max		78.0	75.0	2.0	1120.0	41.0	1.3	