

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE OBTAINED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
WOODENBONG	15/07/2020	24/07/2020	5	2	2	14	7.6	0.24	No discharge. Representative sample only
	19/08/2020	24/08/2020	152	3	2	23	4.9	0.42	No discharge representative sample only
	Min		5.0	2.0	2.0	14.0	4.9	0.2	
	Avg		78.5	2.5	2.0	18.5	6.3	0.3	
	Max		152.0	3.0	2.0	23.0	7.6	0.4	