

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE OBTAINED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
BONALBO	15/07/2020	24/07/2020	131	41	2	921	8.1	5.9	No discharge. Representative sample only
	21/10/2020	4/11/2020	213	76	5	3	14	4	
	20/01/2021	27/01/2021	108	27	2	3835	7.2	2.8	
	17/02/2021	25/02/2021	124	24	2	598	8.6	2.9	
	17/03/2021	29/03/2021	85	28	2	16275	8.3	2.9	
	22/04/2021	3/05/2021	48	27	2	19863	11	3.3	
	20/05/2021	1/06/2021	47	22	2	28272	7.8	3.1	
	24/06/2021	8/07/2021	70	39	2	97688	8.8	5.5	
	Min		47.0	22.0	2.0	3.0	7.2	2.8	
	Avg		103.3	35.5	2.4	20931.9	9.2	3.8	
	Max		213.0	76.0	5.0	97688.0	14.0	5.9	