

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE OBTAINED	Total Suspended Solids (mg/L) 90th%ile 15 100th%ile 30	Biological Oxygen Demand (mg/L) 90th%ile 10 100th%ile 20	Oils and Grease (mg/L) 90th%ile 5 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) 90th%ile 10 100th%ile 40	Total Phosphorus (mg/L) 90th%ile 2 100th%ile 5	COMMENTS
KYOGLE	1/07/2020	14/07/2020	1	3	2	148	7.3	1.4	Compliant
	15/07/2020	24/07/2020	1	6	2	86	4	1.6	Compliant
	5/08/2020	18/08/2020	24	11	2	816	2.5	2.1	Compliant Above 90%ile TP
	19/08/2020	24/08/2020	8	5	2	866	4.3	2	Compliant
	2/09/2020	14/09/2020	13	9	2	17329	5.4	3.2	Above 90%ile for P
	2/09/2020	2/09/2020	13	9	2	17329	5.4	3.2	
	7/10/2020	7/10/2020	2	3	2	66	6.5	3.7	
	21/10/2020	4/11/2020	4	2	4	184	5.8	4.2	
	6/01/2021	13/01/2021	3	2	2	816	2.3	1.3	
	20/01/2021	27/01/2021	16	4	2	19863	6.7	0.99	
	3/02/2021	8/02/2021	3	2	2	1017	2.4	0.87	
	17/02/2021	25/02/2021	22	9	2	21430	8.9	1.2	
	3/03/2021	12/03/2021	8	3	2	25994	5.7	0.97	
	17/03/2021	29/03/2021	18	4	2	54750	2.7	1.3	
	1/04/2021	13/04/2021	6	3	2	1080	4.2	0.69	
	22/04/2021	3/05/2021	72	2	2	1870	2.9	0.67	
	20/05/2021	1/06/2021	7	3	2	155	7.7	0.44	
	3/06/2021	16/06/2021	31	13	2	1664	18	0.89	
	24/06/2021	8/07/2021	4	3	2	350	10	0.37	
		Min		1.0	2.0	2.0	66.0	2.3	0.4
	Avg		13.5	5.1	2.1	8727.0	5.9	1.6	
	Max		72.0	13.0	4.0	54750.0	18.0	4.2	