

KYOGLE COUNCIL EPA RESULTS TABLE

TEST LOCATION	TEST DATE	DATE OBTAINED	Total Suspended Solids (mg/L) 100th%ile 30	Biological Oxygen Demand (mg/L) 100th%ile 20	Oils and Grease (mg/L) 100th%ile 10	Faecal Coliforms (cfu/100mL) no limits	Total Nitrogen (mg/L) no limits	Total Phosphorus (mg/L) no limits	COMMENTS
WOODENBONG	15/07/2020	24/07/2020	5	2	2	14	7.6	0.24	No discharge. Representative sample only
	19/08/2020	24/08/2020	152	3	2	23	4.9	0.42	No discharge representative sample only
	20/10/2020	4/11/2020	10	8	2	15	5.6	1.2	
	20/01/2021	27/01/2021	76	4	2	1553	2	0.28	
	17/02/2021	25/02/2021	12	9	2	91	2.6	0.98	
	17/03/2021	29/03/2021	41	9	2	613	3.6	1.1	
	22/04/2021	3/05/2021	33	8	2	21	3.7	1.3	
	20/05/2021	1/06/2021	17	5	2	1	3.5	1.4	
	24/06/2021	8/07/2021	33	12	2	11	5.3	1.8	
	Min		5.0	2.0	2.0	1.0	2.0	0.2	
	Avg		42.1	6.7	2.0	260.2	4.3	1.0	
	Max		152.0	12.0	2.0	1553.0	7.6	1.8	