

Kyogle Council - EPA Results Table
Woodenbong Sewerage Treatment Plant - Licence Number 833



Site	Date Test Taken		pH	Conductivity (EC) (dS/m)	Total Dissolved Salts (mg/L)	Total Oils and Grease (mg/L)	Total Suspended Solids (mg/L)	Biochemical Oxygen Demand ₅ (mg/L O ₂)	Total Phosphorus (mg/L P)	Total Nitrogen (mg/L N)	Faecal Coliforms (cfu/100 ml)	E.Coli (cfu/100 ml)	Comments
Licenced Discharge Point (Point1)	16/07/2025		8.76	0.50	341.00	< 2	20.00	9.45	1.70	2.61	30000	400	
	20/08/2025		8.60	0.48	328.00	< 2	15.00	5.85	1.86	2.18	12400	2700	
	17/09/2025		9.81	0.51	347.00	< 2	18.00	5.30	2.12	2.07	<10	100	
Effluent reuse (Point 5)	16/07/2025										40000	40	No effluent reuse this month
	20/08/2025										<10	<10	
	17/09/2025										30	10	
90th%ile limit													
100th%ile limit						10	30	20			1000		
Min			8.60	0.48	328.00	<2	15.00	5.30	1.70	2.07	12400	100	
Avg			9.06	0.50	338.67	<2	17.67	6.87	1.89	2.29	21200	1067	
Max			9.81	0.51	347.00	<2	20.00	9.45	2.12	2.61	30000	2700	